

ADDENDUM NUMBER #1

<u>PROJECT</u>	<u>BIDS DUE</u>
DPW Standby Generator Proposal Grand Traverse County 2650 LaFranier Road Traverse City, MI 49686	<i>Date: August 20, 2019 @ 4 P.M.</i>

The Addendum is issued prior to the receipt of bid proposals to amend the Contract Documents as follows. Bidders shall acknowledge receipt of this addendum by signed and submitting this form along with bid proposal.

1. The existing site has topographic and site constraint challenges the contractor must work within. It is **STRONGLY** encouraged the contractor to visit the site prior to soliciting a bid. All storage, staging, and installation of equipment shall be within the public right of way and existing easement.
2. In addition to site work as noted in the RFP and installation of the concrete pad, contractor shall include installation of permanent sheeting to provide flat, rigid support of equipment and maintain slope stability. The shoring must meet "Great Lakes" waterfront duty, corrugated piling or other "Wave and ice-proof" shoring shall be provided and subject to shop drawing submission and engineer approval prior to installation.
3. List loads and steps to be served – all must bid equipment to comply for either across the line start – or – for use with VFD if installed in the future.
 - Step One:
 - 15kVA misc load fed by step down transformers
 - Pump #1 25HP 480VAC A-T-L Code F, but must allow for 32RLA per the motor nameplate RLA
 - 1/2HP Fan. 120VAC single phase
 - 2 ¾ HP Sump Pump 480VAC Code N staged
 - Step Two:
 - Second 25HP Pump package with motor details the same Step One (must allow for 32RLA)
4. 125 Amp Industrial ATS shall be provided to match current service (100 Amp disconnect) and NOT a 225 Amp ATS.

This Addendum No. 1 becomes part of the Contract Documents as of this date and supersedes the information in the originally issued Contract Documents where applicable. The Contractor shall acknowledge receipt of the Addendum by signing and submitting with bid proposal. By signing the bidder understands, acknowledges and agrees to comply with this addendum.

Signature